



MIKE SPANO
MAYOR
ROBERT F. SWEENEY
COMMISSIONER

CITY OF YONKERS

FIRE DEPARTMENT

470 NEPPERHAN AVENUE 2ND FLOOR

YONKERS, NEW YORK 10701

(914) 377-7500 FAX (914) 377-7560



NOTICE TO BUILDING OWNERS AND OPERATORS

The 2010 Fire Code of New York State Section 901.6.2 requires records of all fire protection system inspections, tests and maintenance shall be maintained on the premises for a minimum of ten (10) years and shall be copied to the code enforcement official on request. Pursuant to this requirement, beginning April 15, 2013, records of the system(s) listed below shall be copied to the Yonkers Fire Department.

Fire Protection System Maintenance Standards

SYSTEM	STANDARD
Portable fire extinguishers	NFPA 10
Carbon dioxide fire-extinguishing system	NFPA 12
Halon 1301 fire-extinguishing systems	NFPA 12A
Dry-chemical extinguishing systems	NFPA 17
Wet-chemical extinguishing systems	NFPA 17A
Private Service Tanks	NFPA 24
Water Tanks	NFPA 25
Water-based fire protection systems	NFPA 25
Fire alarm systems	NFPA 72
Water-mist systems	NFPA 750
Clean-agent extinguishing systems	NFPA 2001
Commercial Kitchen Hoods	NFPA 96

Inspection records shall be submitted (postmarked or hand delivered) within ten (10) business days from the date of inspection. All records shall be addressed to:

Yonkers Fire Department
Fire Prevention Division
Attn: Maintenance Records Reporting
470 Nepperhan Avenue 2nd Floor
Yonkers, NY 10701

Any questions regarding the above information may be submitted to the Fire Prevention Division at (914) 377-7525.